LEGEND

- PROPERTY LINE
- 1.5% — PROPOSED SWALE AND DIRECTION OF FLOW
- CAR ONLY PARKING AREA
- EXISTING EDGE OF GRAVEL SHOULDER
- EXISTING CENTERLINE OF DITCH
- EXISTING CENTERLINE OF ROAD
- 95.55 — EXISTING ELEVATION (AOV SURVEY POINTS)
- 93.00 — EXISTING ELEVATION (NOVATECH SURVEY POINTS)
- 95.55 / 95.20 — PROPOSED ELEVATION / EXISTING ELEVATION
- 93.00(S) — PROPOSED SWALE INVERT ELEVATION
- 93.15TC — PROPOSED TOP OF CURB ELEVATION
- A A — CROSS SECTIONS, REFER TO 124111-ND FOR DETAILS
- TERRACING: MAXIMUM 3:1 SIDESLOPE
- 2.0% — GRADE AND DIRECTION
- FFE= — FINISHED FLOOR ELEVATION
- DC — PROPOSED DEPRESSED CURB
- HP — PROPOSED GRADING HIGH POINT
- GRAVEL AREA
- PROPOSED SIDEWALK
- ENTRY DOOR
- PROPOSED CULVERT
- DIRECTION OF MAJOR OVERLAND FLOW
- TACTILE WALKING SURFACE INDICATOR (TWSI)

GRADING NOTES:

1. ALL TOPSOIL, ORGANIC OR DELETERIOUS MATERIAL MUST BE ENTIRELY REMOVED FROM BENEATH THE PROPOSED PAVED AREAS AS DIRECTED BY THE SITE ENGINEER OR GEOTECHNICAL ENGINEER.
2. EXPOSED SUBGRADES IN PROPOSED PAVED AREAS SHOULD BE PROOF ROLLED WITH A LARGE STEEL DRUM ROLLER AND INSPECTED BY THE GEOTECHNICAL ENGINEER PRIOR TO THE PLACEMENT OF GRANULARS.
3. ANY SOFT AREAS EVIDENT FROM THE PROOF ROLLING SHOULD BE SUB-EXCAVATED AND REPLACED WITH SUITABLE MATERIAL THAT IS FROST COMPATIBLE WITH THE EXISTING SOILS AS RECOMMENDED BY THE GEOTECHNICAL ENGINEER.
4. THE PAVEMENT GRANULAR BASE AND SUBBASE SHOULD BE PLACED IN 300mm THICK LIFTS AND COMPACTED TO A MINIMUM OF 99% OF THE MATERIAL'S SPMDD USING SUITABLE COMPACTION EQUIPMENT.
5. MINIMUM OF 2% GRADE FOR ALL GRASS AREAS UNLESS OTHERWISE NOTED.
6. MAXIMUM TERRACING GRADE TO BE 3:1 UNLESS OTHERWISE NOTED.
7. ALL GRADES BY CURBS ARE EDGE OF PAVEMENT GRADES UNLESS OTHERWISE INDICATED.
8. ALL CURBS SHALL BE BARRIER CURB (150mm) UNLESS OTHERWISE NOTED AND CONSTRUCTED AS PER CITY OF OTTAWA STANDARDS (SC1.1).
9. REFER TO LANDSCAPE PLAN FOR PLANTING AND OTHER LANDSCAPE FEATURE DETAILS.
10. CONTRACTOR TO PROVIDE THE CONSULTANT WITH A GRADING PLAN INDICATING AS-BUILT ELEVATIONS OF ALL DESIGN GRADES SHOWN ON THIS PLAN.
11. ALL ELEVATIONS ARE GEODETIC AND ARE REFERRED TO THE CGVD28 GEODETIC DATUM. THE SITE BENCHMARK IS LOCATED ON THE UNDERSIDE OF THE WELL CASING CAP AND IS ELEVATION 90.18m. BEARINGS ARE REFERENCED TO THE CENTRAL MERIDIAN OF MTM ZONE 9, NAD83 (CSRS)(2010). REFER TO "PLAN OF SURVEY OF BLOCK 2, REGISTERED PLAN 4M-1388, CITY OF OTTAWA, BY ANNIS O'SULLIVAN VOLLBEKK LTD.
12. ALL LANDSCAPE DRAIN T/G SHALL BE INSTALLED 5cm ABOVE THE BOTTOM OF SWALE ELEVATIONS TO PROMOTE INFILTRATION.
13. THE PAVEMENT AND GRAVEL SURFACE STRUCTURES NOTED ON THIS PLAN ARE AS PER THE GEOTECHNICAL CONSULTANTS RECOMMENDATION. REFER TO GEOTECHINCAL REPORT (No. PG7327-1 REV. 1, DATED AUGUST 21, 2025) FOR COMPLETE DETAILS.

PAVEMENT STRUCTURE:

CAR ONLY PARKING AREA
50mm SUPERPAVE 12.5 SURFACE COURSE
150mm OPSS GRANULAR A BASE COURSE
300mm OPSS GRANULAR B TYPE II SUBBASE

ACCESS LANES
40mm SUPERPAVE 12.5 SURFACE COURSE
50mm SUPERPAVE 19.0 BINDER COURSE
150mm OPSS GRANULAR A BASE COURSE
450mm OPSS GRANULAR B TYPE II SUBBASE

GRAVEL STRUCTURE:

300mm OPSS GRANULAR A BASE COURSE
450mm OPSS GRANULAR B TYPE II SUBBASE




HIP SWMF BOTTOM OF POND (APPROXIMATE LOCATION)
REFER TO THE JLR "HAWTHORNE INDUSTRIAL PARK SWMF AND GRADING PLAN"DATED MAY 28TH, 2009 FOR MORE DETAILS.
HIP SWMF TOP OF BERM (APPROXIMATE LOCATION)
MATCH INTO EXISTING ELEVATIONS AT PROPERTY LINE (TYP.)
TERMINATE CURB WITH A 1.5m CURB TRANSITION
MATCH INTO EXISTING 3:1 MAX
MATCH INTO EXISTING 3:1 MAX. ALL AREAS ON ADJACENT PROPERTY THAT REQUIRE RE-GRADING ARE TO BE PROVIDED WITH 100mm TOPSOIL AND SEED.
1 CC 35 MAT - TITAN ARTICULATED CONCRETE BLOCK REVETMENT SYSTEM (RIP-RAP ALTERNATIVE) C/W DECORATIVE STONE WALL (SEE 124111-ND FOR DETAILS)
LD4 T/G=88.90
LD3 T/G=88.82
MANTLE
190m³ SEPTIC FIELD
ZONING SETBACK
DISPERSION BED
4 x 5.0 m 75mmØ DISTRIBUTION PIPES
TERMINATE CURB WITH A 1.5m CURB TRANSITION
RIP RAP AS PER OPSD 810.010
CBMH 102 T/G=88.90
CONCRETE OUTLET AS PER OPSD 604.010
OGS T/G=89.25
PROPOSED BARRIER CURB
MATCH INTO EXISTING ASPHALT ELEVATIONS, SAW CUT AND KEY GRIND AS PER CITY DETAIL R10.
12' WIDE OVERHEAD DOOR
FLOOR DRAIN C/W OGS
1 STORY+ MEZZANINE WAREHOUSE F.F.E'= 89.90 U.S.F = 87.97
MEZZANINE/OFFICE SPACE OUTLINE
COVERED PORCH
BIOFILTER TANK INLET T/G = 89.93 OUTLET T/G = 89.97
ANEROBIC DIGESTER TANK INLET T/G = 89.90 OUTLET T/G = 89.89
(2x) 15.95m-700mmØ CSP @1.00%
CONCRETE CURB TO TERMINATE AT PL. TERMINATION AS PER OPSD 608.010.
1.8m WIDE SIDEWALK
FLUSH CURB
LIMIT OF LEAN-TO OVER HANG
CAR ONLY PARKING AREA
CB 101 T/G=89.35
PROPOSED WELL GROUND ELEV. = 89.86 TOP OF WELL CASING = 90.26
SITE BENCHMARK PAINT MARK ON TOP OF WELL CASING (UNDER CAP)) ELEVATION = 90.18
Somme Street
REGRADE EXISTING DITCH TO ACHIEVE POSITIVE FLOW
(2x) 15.37m-700mmØ CSP @1.00%
MATCH INTO EXISTING ASPHALT ELEVATIONS, SAW CUT AND KEY GRIND AS PER CITY DETAIL R10.
CONCRETE CURB TO TERMINATE AT PL. TERMINATION AS PER OPSD 608.010.
CBMH 100 T/G=89.20
LD2 T/G=89.32
LD1 T/G=89.45
MATCH INTO EXISTING ELEVATIONS AT PROPERTY LINE (TYP.)
EXISTING TREE LINE
ASPHALT
GRAVEL
HP
DS1
DS2
DS3
DS4
DS5
DS6
DS7
DS8
DS9
DS10
DS11
DS12
DS13
DS14
DS15
DS16
DS17
DS18
DS19
DS20
DS21
DS22
DS23
DS24
DS25
DS26
DS27
DS28
DS29
DS30
DS31
DS32
DS33
DS34
DS35
DS36
DS37
DS38
DS39
DS40