



Legend

	PROPOSED WATERMAIN
	PROPOSED VALVE AND VALVE BOX
	PROPOSED VALVE CHAMBER
	PROPOSED W3 CHAMBER
	PROPOSED REDUCER
	PROPOSED FIRE HYDRANT
	PROPOSED SANITARY SEWER
	PROPOSED STORM SEWER
	PROPOSED CATCHBASIN MANHOLE
	PROPOSED CATCHBASIN
	PROPOSED CBT AND SUBDRAIN
	EXISTING WATERMAIN
	EXISTING VALVE AND VALVE BOX
	EXISTING VALVE CHAMBER
	EXISTING REDUCER
	EXISTING FIRE HYDRANT
	EXISTING COMBINED SEWER
	EXISTING STORM SEWER
	EXISTING CATCHBASIN MANHOLE
	EXISTING CATCHBASIN
	PROPOSED DEPRESSED CURB LOCATIONS
	PROPOSED BARRIER CURB
	THERMAL INSULATION ON STORM SEWER WHERE COVER IS LESS THAN 2.0m AND ON SANITARY SEWER WHERE COVER IS LESS THAN 2.5m AS PER S35. INSULATION OVER WATERMAIN PER W22 WHERE COVER IS LESS THAN 2.4m
	WATER METER
	REMOTE WATER METER
	PROPOSED 2HR RATED FIRE WALL LOCATION
	<u>BACK TO BACK TACK HOME SERVICES</u> 200mm STORM SERVICE PVC SDR 28 @ 1% MIN 150mm SANITARY SERVICE PVC SDR 28 @ 1% MIN 19mm PEH TUBING WATER SERVICE C/W CURB STOP AND SERVICE POST

5/11/2019-05:21
SAN/IN-053.32

A circular blue ink stamp. The outer ring contains the text "LICENSED PROFESSIONAL ENGINEER" at the top and "PROVINCE OF ONTARIO" at the bottom. In the center, there is a signature "K.L. Smaedella" in blue ink. Below the signature, the text "K.L. SMADELLE" is printed in blue. At the bottom center, the date "2026-09-02" is printed in blue.

Title
SITE SERVICING PLAN

SSP-1 3 of 7 5
PLAN # 19393

ORIGINAL SHEET - ARCH ID:

007-12-25-0148